

CITY OF AUSTIN
2nd Quarter 2026

Average Results for Samples Collected April 1, 2026 to June 30, 2026

CONSTITUENT (mg/L)	DWTP Raw	UWTP Raw	HWTP Raw	DWTP Tap	UWTP Tap	HWTP Tap	SDWA Tap MCL/[SMCL]
Calcium	41	41	40	12	15	14	
Conductivity (umhos/cm)	412	407	402	271	280	305	
E.Coli (MPN/100ml)	7	11	<1	<1	<1	<1	
Fluoride	0.18	0.18	0.18	0.62	0.72	0.62	4/[2]
Free Ammonia (as N)	<0.050	<0.050	<0.050	0.079	0.134	0.106	
Magnesium	14	14	14	11	10	10	
Threshold Odor (TON)	4	4	4	0	0	0	[3]
pH (units)	8.03	8.06	8.26	9.70	9.74	9.65	[>7.0]
Phenol Alkalinity (as CaCO ₃)	0	0	0	16	16	16	
Silica	7.72	7.38	8.07	7.21	6.69	7.06	
Sulfate	15.9	16.1	15.7	20.0	21.1	21.6	
Total Alkalinity (as CaCO ₃)	142	141	141	52	51	60	
Total Ammonia (as N)	&	&	&	&	&	&	
Total Chloramines	&	&	&	2.69	2.52	2.60	
Total Coliform (MPN/100ml)	1176	1412	80	<1	<1	<1	
Total Hardness (as CaCO ₃)	161	161	157	76	77	77	
Total Organic Carbon	4.89	4.93	4.63	3.45	3.25	3.32	
Total Phosphate	<0.050	<0.050	<0.050	0.934	0.930	0.922	
Total Solids	255	240	227	156	154	154	[500]
Turbidity (NTU)	1.25	1.04	0.77	0.067	0.051	0.051	0.3
UV254 (cm ⁻¹)	0.115	0.114	0.109	0.074	0.067	0.067	

< set of averaged measurements contains results that are less than the method detection limit

Parameters listed below were collected and analyzed by TCEQ Contractors for compliance with the Safe Drinking Water Act.

CONSTITUENT (mg/L)	DWTP Raw	UWTP Raw	HWTP Raw	Central Tap	Detection Limit	South Tap	Detection Limit	North Tap	Detection Limit	SDWA Tap MCL/[SMCL] in mg/L
Disinfection By Products, Collected On:				5/4/2026		5/4/2026		5/4/2026		
Haloacetic Acids (HAA5)	&	&	&	0.0155		0.0123		0.0141		0.060
Trihalomethane	&	&	&	0.0462		0.0434		0.0521		0.080
CONSTITUENT (mg/L)	DWTP Raw	UWTP Raw	HWTP Raw	DWTP Tap	Detection Limit	UWTP Tap	Detection Limit	HWTP Tap	Detection Limit	SDWA Tap MCL/[SMCL] in mg/L
Pesticides, Collected On:				2/12/2025		2/12/2025		5/2/2024		
Endrin	&	&	&	ND	0.00001	ND	0.00001	ND	0.00001	0.002
Lindane	&	&	&	ND	0.00002	ND	0.00002	ND	0.00002	0.0002
Methoxychlor	&	&	&	ND	0.0001	ND	0.0001	ND	0.0001	0.04
Inorganics, Collected On:				2/12/2025		2/5/2026		5/4/2026		
Chloride	&	&	&	52		34		44		[250]
Metals, Collected On:				2/12/2025		2/5/2026		5/4/2026		
Aluminum	&	&	&	ND	0.0200	ND	0.0200	ND	0.0200	[0.05 - 0.2]
Antimony	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.006
Arsenic	&	&	&	ND	0.0020	ND	0.0020	ND	0.0020	0.01
Barium	&	&	&	0.009		0.0110		0.0135		2
Beryllium	&	&	&	ND	0.00080	ND	0.00080	ND	0.00080	0.004
Cadmium	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.005
Chromium	&	&	&	ND	0.0100	ND	0.0100	ND	0.0100	0.1
Copper	&	&	&	ND	0.0020	ND	0.0020	0.0056		1.3 **
Iron	&	&	&	0.018		0.027		0.011		[0.3]
Lead	&	&	&	ND	0.0010	ND	0.010	ND	0.0010	0.015 **
Manganese	&	&	&	ND	0.0010	ND	0.010	ND	0.0010	[0.05]
Mercury	&	&	&	ND	0.00040	ND	0.010	ND	0.00040	0.002
Nickel	&	&	&	ND	0.0010	ND	0.010	ND	0.0010	[0.10]
Selenium	&	&	&	ND	0.0030	ND	0.010	ND	0.0030	0.05
Silver	&	&	&	ND	0.0100	ND	0.010	ND	0.0100	[0.1]
Sodium	&	&	&	28.5		18.6		26.4		---
Thallium	&	&	&	ND	0.00040	ND	0.00040	ND	0.00040	0.002
Zinc	&	&	&	ND	0.0050	ND	0.0050	ND	0.0050	[5.0]

SDWA MCL = Safe Drinking Water Act Maximum Contaminant Level

SMCL = Secondary Maximum Contaminant Level standard recommended by TCEQ for aesthetic quality

** = Action Levels

ND = Indicates levels are below detection limits of the instrumentation or method

& = No data available

col/100ml = Colonies per 100 milliliters

mg/L = milligrams per liter