Austin Water

CITY OF AUSTIN
3rd Quarter 2026

Average Results for Samples Collected July 1, 2026 to September 30, 2026										
CONSTITUENT (mg/L)	**DWTP Raw**	**UWTP Raw**	**HWTP Raw**	**DWTP Tap**		**UWTP Tap**		**HWTP Tap**		**SDWA Tap MCL/[SMCL]**
Calcium	41	41	39	12		14		13		
Conductivity (umhos/cm)	415	413	396	264		269		293		
E.Coli (MPN/100ml)	13	9	<1	<1		<1		<1		
Fluoride	0.19	0.18	0.18	0.64		0.69		0.57		4/[2]
Free Ammonia (as N)	<0.050	<0.050	<0.050	0.101		0.126		0.119		
Magnesium	14	15	14	10		10		9		
Threshold Odor (TON)	4	4	4	0		0		0		[3]
pH (units)	8.00	7.96	8.04	9.73		9.78		9.70		[>7.0]
Phenol Alkalinity (as $CaCO_3$)	0	0	0	15		17		16		
Silica	9.06	9.07	8.23	7.77		7.82		7.08		
Sulfate	19.2	19.6	15.2	22.9		21.5		21.0		
Total Alkalinity (as $CaCO_3$)	144	142	140	49		53		54		
Total Ammonia (as N)	&	&	&	0.551		0.581		0.694		
Total Chloramines	&	&	&	2.88		2.75		2.80		
Total Coliform (MPN/100ml)	2949	3771	2542	<1		<1		<1		
Total Hardness (as $CaCO_3$)	160	162	155	70		75		70		
Total Organic Carbon	4.75	4.85	4.59	3.06		3.07		2.96		
Total Phosphate	<0.050	<0.050	<0.050	0.882		1.03		0.740		
Total Solids	248	243	223	145		149		154		[500]
Turbidity (NTU)	1.50	1.11	1.38	0.062		0.051		0.058		0.3
UV254 (cm^{-1})	0.109	0.110	0.103	0.061		0.063		0.058		

< set of averaged measurements contains results that are less than the method detection limit

Parameters listed below were collected and analyzed by TCEQ Contractors for compliance with the Safe Drinking Water Act.										
CONSTITUENT (mg/L)	**DWTP Raw**	**UWTP Raw**	**HWTP Raw**	**Central Tap**	**Detection Limit**	**South Tap**	**Detection Limit**	**North Tap**	**Detection Limit**	**SDWA Tap MCL/[SMCL] in mg/L**
Disinfection By Products, Collected On:				**8/6/2026**		**8/6/2026**		**8/6/2026**		
Haloacetic Acids (HAA5)	&	&	&	0.0193		0.0145		0.0204		0.060
Trihalomethane	&	&	&	0.0472		0.0431		0.0542		0.080
CONSTITUENT (mg/L)	**DWTP Raw**	**UWTP Raw**	**HWTP Raw**	**DWTP Tap**	**Detection Limit**	**UWTP Tap**	**Detection Limit**	**HWTP Tap**	**Detection Limit**	**SDWA Tap MCL/[SMCL] in mg/L**
Pesticides, Collected On:				**8/6/2026**		**2/5/2026**		**5/2/2024**		
Endrin	&	&	&	ND	0.00001	ND	0.00001	ND	0.00001	0.002
Lindane	&	&	&	ND	0.00002	ND	0.00002	ND	0.00002	0.0002
Methoxychlor	&	&	&	ND	0.0001	ND	0.0001	ND	0.0001	0.04
Inorganics, Collected On:				**8/6/2026**		**2/5/2026**		**5/4/2026**		
Chloride	&	&	&	35		34		44		[250]
Metals, Collected On:				**8/6/2026**		**2/5/2026**		**5/4/2026**		
Aluminum	&	&	&	ND	0.0200	ND	0.0200	ND	0.0200	[0.05 - 0.2]
Antimony	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.006
Arsenic	&	&	&	ND	0.0020	ND	0.0020	ND	0.0020	0.01
Barium	&	&	&	0.0106		0.0110		0.0135		2
Beryllium	&	&	&	ND	0.00080	ND	0.00080	ND	0.00080	0.004
Cadmium	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.005
Chromium	&	&	&	ND	0.0100	ND	0.0100	ND	0.0100	0.1
Copper	&	&	&	0.0029	`	ND	0.0020	0.0056		1.3 **
Iron	&	&	&	ND	0.010	0.027		0.011		[0.3]
Lead	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	0.015 **
Manganese	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	[0.05]
Mercury	&	&	&	ND	0.00040	ND	0.00040	ND	0.00040	0.002
Nickel	&	&	&	ND	0.0010	ND	0.0010	ND	0.0010	[0.10]
Selenium	&	&	&	ND	0.0030	ND	0.0030	ND	0.0030	0.05
Silver	&	&	&	ND	0.0100	ND	0.0100	ND	0.0100	[0.1]
Sodium	&	&	&	18.6		18.6		26.4		---
Thallium	&	&	&	ND	0.00040	ND	0.00040	ND	0.00040	0.002
Zinc	&	&	&	ND	0.0050	ND	0.0050	ND	0.0050	[5.0]

SDWA MCL = Safe Drinking Water Act Maximum Contaminant Level
SMCL = Secondary Maximum Contaminant Level standard recommended by TCEQ for aesthetic quality
** = Action Levels
ND = Indicates levels are below detection limits of the instrumentation or method
& = No data available
col/100ml = Colonies per 100 milliliters mg/L = milligrams per liter